



Jal Jeevan Mission

Har Ghar Jal



District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Gonda

Office of Executive Engineer, Construction division, U.P Jal Nigam, near PAC gate No-2, Gonda. Pin-271001 (Test Address only)

Test report

Certificate number:

TC-13232

Sample Id:

U2829975534147603

User Information

Name:

Dr Madhup Mishra

Mobile:

9151649000

Email:

ips.ayodhya@gmail.com

Pin Code:

271303

Full Address:

Village- Turkouli, Gram Panchayat- Turkouli, Block- Nawabganj, District- Gonda, State- Uttar Pradesh

Sample description

Source of Sample:

Indirapuram Public School Tap water

Village:

Turkouli

Gram Panchayat:

Turkouli

Block:

Nawabganj

District:

Gonda

State:

Uttar Pradesh

Address:

Remarks:

Latitude:

26.854163

Longitude:

82.174904

Date & time of sample collection

13.01.2026 | 03:38:00 PM

Date & time of sample received in lab

13.01.2026 | 03:47:00 PM

Date & time of sample analysed

17.01.2026 | 10:19:00 AM

Date & time of report generation

19.01.2026 | 10:23:08 AM

Test results


S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Chloride (as Cl)*	mg/l	250	1000	20.000	Argentometric method	
2	Fluoride (as F)*	mg/l	1	1.5	0.001	Ion selective electrode method	
3	Iron (As Fe)*	mg/l	1	No Relaxation	0.004	Phenanthroline method or as per IS 15303:2002 Electrothermal atomic absorption/Spectrophotometer method	
4	Nitrate (as NO ₃)*	mg/l	45	No Relaxation	0.820	UV-Visible Spectrophotometer	
5	pH*	NA	6.5-8.5	No Relaxation	7.160	Electrometric method	
6	Sulphate (as SO ₄)*	mg/l	200	400	2.100	Turbidimetric method	
7	TDS*	mg/l	500	2000	99.000	Gravimetric method	
8	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	69.000	Titration method	
9	Total Hardness (As CaCO ₃)*	mg/l	200	600	79.000	EDTA Titrimetric method	
10	Turbidity*	NTU	1	5	0.050	Nephelometric method	

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Data prepared by

Chemist: (sameer vaish)


Authorised signatory

Pashupati Nath (Test Lab Incharge)

*****This is an electronically generated report and does not require a signature.*****

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TC-13232

Dated: 19/01/2026

It is certified that an inspection team headed by Pashupati Nath Technical Manager

(Name of Officers with designation) from Gonda PHED

inspected the Indirapuram Public School, Turkauli, Nawabganj, Gonda. U.P.- 271303

on 13/01/2026 and on the basis of Water Test Report (Attached) bearing

no. U 2829975834147603 dated 19/01/2026

of Gonda (PHED Lab) certified that the

Indirapuram Public School, Turkauli, Nawabganj, Gonda U.P.- 271303 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 19/01/2028

Technical Manager

District Level Water Analysis Laboratory
Gonda, U.P.

Signature with Seal: PASHUPATI NATH

Name : PASHUPATI NATH

Designation : Chemist

Name & Address of the Office / Department :

To
Indirapuram Public School
Turkauli, Nawabganj, Gonda-271303

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies